

**PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION  
CERTIFICATE.**

No. 910Date: 21/04/2023

It is certified that an inspection team headed by Shri. Dipesh Kumar  
Junior Engineer (Name of Officers  
with designation) from Public Health Division Kishanganj (Name of  
Department/Office) inspected the Oriental Public School  
Tegharia Kishanganj Bihar 855107 (Name & Address of  
the School) on 30-03-2023 and found that the Oriental Public  
school Tegharia Kishanganj (Name of school) has safe  
drinking water facilities for the students and members of staff of the institution and is maintaining  
the hygienic sanitation condition in the school building & the campus as per the norms  
prescribed by the Central/State/U.T Govt

The above valid for a period of One Year

Dipesh Kumar  
21/4/23  
Signature with Seal: Junior Engineer  
P.H. Section, Dighalbank  
Name: Dipesh Kumar

Designation: Junior Engineer

To:

Oriental Public School  
Tegharia Kishanganj  
Bihar 855107

(Name &amp; Address of the Institution)

Principal  
21/4/23

**ORIENTAL PUBLIC SCHOOL**  
TEGHARIA, KISHANGANJ  
Aff. No.-330480  
School No.-65455

Daya Shankar Prasad  
21/4/23  
Signature with Seal: Executive Engineer  
P.H. Division, Kishanganj

Name: Daya Shankar Prasad

Designation: Executive Engineer  
P.H. Division Kishanganj

Daya Shankar Prasad  
16-06-23  
Signature  
Manager  
**ORIENTAL PUBLIC SCHOOL**  
TEGHARIA, KISHANGANJ

**OFFICE OF THE EXECUTIVE ENGINEER  
PUBLIC HEALTH DIVISION KISHANGANJ**

**Physico-Chemical Examination Report of Drinking Water Sample of Kishanganj**

Sample Collected By: -School Staff

Sl.No	Block	Panchayat	Location	PH	Fe	TH	Alkalinity	Ca	Mg	Cl	Cond.	T.D.S	Remarks
1	Kishanganj	Nagar	Oriental Public School Teghariya Kishanganj (Treated Water)	6.9	0.4	56	62	16	4	26	132	86	Treated Water
Desirable limit				6.5-8.5	1.0 mg/l	200 mg/l	200mg/l	75mg/l	30mg/l	250mg/l	---	500 mg/l	
Permissible Limit in absence of alternate source				NR	NR	600 mg/l	600mg/l	200mg/l	100mg/l	1000mg/l	---	2000 mg/l	
IS:10500 :2012													

P.H. Division Kishanganj

Lab Assistant

*Patil*  
31/03/2023

P.H. Division. Kishanganj

Chemist

*SP*  
31/03/2023

P.H. Sub. Division Kishanganj

Assistant Engineer

*SP*

P.H. Division Kishanganj

Executive Engineer

*Patil*  
31/3/23

**ORIENTAL PUBLIC SCHOOL**  
TEGHARIA, KISHANGANJ  
Aft. No.-330480  
School No.-65455

*Principal*  
31/03/23

**ORIENTAL PUBLIC SCHOOL**

Manager

*Patil*  
31/03/23