

Annexure - C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

NO. 252

Date 05.02.2025

It is certified that an inspection team headed by Gulam Nabi Azad, Junior Engineer (Name of Officers with designation) From Nagar Parishad, Kishanganj PHED inspected the **ORIENTAL PUBLIC SCHOOL, Tegharia, Kishanganj** (Name & Address of the School) on 05.02.2025 (date of inspection) and on the basis of Water Test Report (Attached) bearing no. 252 dated 05.02.25 of District Level Water Testing Lab. Kishanganj (PHED Lab) Certified that the **ORIENTAL PUBLIC SCHOOL, Tegharia, Kishanganj** (Name of School) has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/State/U.T. Govt.

This Certificate is valid till One Year.

Gulam Nabi Azad
05/02/2025
J-E

Signature with seal:

Md. Tahir Hassan
Executive Engineer
PHED Division, Kishanganj

Designation :- Executive Engineer

Name & Address of the Office/Department :- Public Health Division, Kishanganj

To,

ORIENTAL PUBLIC SCHOOL,
Tegharia, Kishanganj
(Name & Address of the Institution)

Note :- The certificate is to be issued by authorized officer/PHED Lab/local bodies.

**OFFICE OF THE EXECUTIVE ENGINEER
PUBLIC HEALTH DIVISION KISHANGANJ**

Physico-Chemical Examination Report of Drinking Water Sample of Kishanganj

Sample Collected By: -School Staff							Date of Sample Submission in Lab :- 31.01.25						
District-Kishanganj							Date of Reporting :- 05.02.25						
Sl. No	Block	Panchyat	Location	PH	Fe	TH	Alkalinity	Ca	Mg	Cl	Cond.	T.D.S	Remarks
1	Kishanganj	Nagar	Oriental Public School Teghariya, Kishanganj	7.1	0.53	64	68	18	5	23	150	98	
Desirable limit				6.5-8.5	1.0 mg/l	200 mg/l	200mg/l	75mg/l	30mg/l	250mg/l	500 mg/l	
permissible Limit in absence of alternate source IS:10500 :2012				NR	NR	600 mg/l	600mg/l	200mg/l	100mg/l	1000mg/l	µ mhos/cm	2000 mg/l	

NR- No Relaxation

[Signature]
05/02/25
Lab.Assistant
P.H. Division Kishanganj

[Signature]
05/02/25
Chemist
P.H.Division.Kishanganj

[Signature]
05/2/25
Assistant Engineer
P.H.Sub. Division Kishanganj

[Signature]
06/02/25
Executive Engineer
P.H. Division Kishanganj