

X

### Annexure - C

#### PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

NO...252...

Date...05.02.2025...

It is certified that an inspection team headed by Gulam Nabi Azad, Junior Engineer (Name of Officers with designation) From Nagar Parishad, Kishanganj PHED inspected the **ORIENTAL PUBLIC SCHOOL, Tegharia, Kishanganj** (Name & Address of the School) on 05.02.2025 (date of inspection) and on the basis of Water Test Report (Attached) bearing no...252...dated-...05.02.2025... of District Level Water Testing Lab. Kishanganj (PHED Lab) Certified that the **ORIENTAL PUBLIC SCHOOL, Tegharia, Kishanganj** (Name of School) has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/State/U.T. Govt.

This Certificate is valid till One Year.

[Signature]  
05/02/2025  
 J.E.

Signature with seal: [Signature]  
 Name:- Md. Tahir Hassan  
 Designation :- Executive Engineer

Name & Address of the Office/Department :- Public Health Division, Kishanganj

To,

**ORIENTAL PUBLIC SCHOOL,**  
**Tegharia, Kishanganj** Attested  
**(Name & Address of the Institution)** Awita Saha  
*Manager*

ORIENTAL PUBLIC SCHOOL  
 TEGHARIA, KISHANGANJ

[Signature]  
**ORIENTAL PUBLIC SCHOOL**  
 TEGHARIA, KISHANGANJ  
 Aff. No.-330480  
 School No.-65455

Note :- The certificate is to be issued by authorized officer/PHED Lab/local bodies.

**OFFICE OF THE EXECUTIVE ENGINEER  
PUBLIC HEALTH DIVISION KISHANGANJ  
Physico-Chemical Examination Report of Drinking Water Sample of Kishanganj**

Sample Collected By: -School Staff				Date of Sample Submission in Lab :- 31.01.25									
District-Kishanganj				Date of Reporting :- 05.02.25									
Sl. No	Block	Panchyat	Location	PH	Fe	TH	Alkalinity	Ca	Mg	Cl	Cond.	T.D.S	Remarks
1	Kishanganj	Nagar	Oriental Public School Teghariya, Kishanganj	7.1	0.53	64	68	18	5	23	150	98	
Desirable limit				6.5-8.5	1.0 mg/l	200 mg/l	200mg/l	75mg/l	30mg/l	250mg/l	....	500 mg/l	
permissible Limit in absence of alternate source IS:10500 :2012				NR	NR	600 mg/l	600mg/l	200mg/l	100mg/l	1000mg/l	µ mhos/cm	2000 mg/l	

NR- No Relaxation

*[Signature]*  
05/02/25  
Lab. Assistant  
P.H. Division Kishanganj

*[Signature]*  
05/02/25  
Chemist  
P.H.Division.Kishanganj

*[Signature]*  
05/2/25  
Assistant Engineer  
P.H.Sub. Division Kishanganj

*[Signature]*  
Executive Engineer  
P.H. Division Kishanganj

**Attested**

*Anitasaha*  
Manager  
ORIENTAL PUBLIC SCHOOL  
TEGHARIA, KISHANGANJ

*[Signature]*  
Principal  
ORIENTAL PUBLIC SCHOOL  
TEGHARIA, KISHANGANJ  
Aff. No.-330480  
School No.-65455