

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

NO...415..

Date...19.02.2026

It is certified that an inspection team headed by GULAM NABI AZAD, Junior Engineer (Name of Officers with designation) From P.H. DIVISION, KISHANGANJ PHED inspected the PHED inspected the **ORIENTAL PUBLIC SCHOOL, Tegharia, Kishanganj** (Name & Address of the School) on 19.02.2026 (date of inspection) and on the basis of Water Test Report (Attached) bearing no. 415 dated 19.02.2026 of District Level Water Testing Lab. Kishanganj (PHED Lab) Certified that the **ORIENTAL PUBLIC SCHOOL, Tegharia, Kishanganj** (Name of School) has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/State/U.T. Govt.

This Certificate is valid till One Year.

[Signature]  
19/02/2026  
J.E.

[Signature]  
19/2/26  
AE

[Signature]  
(Signature with seal of Executive Engineer  
P.H. Division, Kishanganj)  
Name:- Md. Nashim Nazar  
Designation :- Executive Engineer

Name &amp; Address of the Office/Department :- Public Health Division, Kishanganj

To,

**ORIENTAL PUBLIC SCHOOL,**  
Tegharia, Kishanganj  
(Name & Address of the Institution)

Note :- The certificate is to be issued by authorized officer/PHED Lab/local bodies.

Anita Saha  
Manager  
ORIENTAL PUBLIC SCHOOL  
TEGHARIA, KISHANGANJ



# DISTRICT LEVEL WATER TESTING LABORATORY

UNDER

P.H. DIVISION KISHANGANJ

## Physico-Chemical Examination Report of Drinking Water Sample of Kishanganj

District-Kishanganj		Date of Reporting :- 19.07.2026													
Sample Collected By:- School Staff.		Date of Reporting :- 14.02.2026													
Sl. No	Block	Panchyat	Location	Turb.	pH	Fe	TH	Alkalinity	Ca	Mg	Cl	Cond.	T.D.S	F	Remarks
1	Kishanganj	Nagar	Oriental Public School, Tegharia, Kishanganj	1.06	6.96	0.47	59.4	65.28	15.84	4.81	16.22	142	92	0.37	
				Desirable limit	1NTU	6.5-8.5	1.0 mg/l	200 mg/l	75mg/l	30mg/l	250mg/l	....	500mg/l	1.0 mg/l	
				Permissible Limit in absence of alternate source	5NTU	NR	600 mg/l	600mg/l	200mg/l	100mg/l	1000mg/l	μ mhos/cm	2000mg/l	1.5mg/l	
				IS:10500 :2012											

NR- No Relaxation

*(Signature)*  
19/07/26

Chemist  
P.H. Division Kishanganj

*(Signature)*  
Assistant Engineer  
P.H. Sub.Division Kishanganj

*Ani-tasaha*  
Manager  
ORIENTAL PUBLIC SCHOOL  
TEGHARIA, KISHANGANJ

*(Signature)*  
ORIENTAL PUBLIC SCHOOL  
TEGHARIA, KISHANGANJ  
Aff. No.-330480  
School No.-65455